

# Certificate of Compliance

Certificate Number 160604 - E242829  
Report Reference E242829, May 20th, 2004  
Issue Date 2004 June 16

Page 1 of 2



*Issued to:*

**CAMOZZI S P A**  
VIA ERITREA 20/1  
I-25126 BRESCIA ITALY

*This is to certify that  
representative samples of*

**Solenoids Operators**

**Models U710, U7H, U77, U771, U75, U73, U76, U79, U7K, U7K1, U72, U74, U71,  
U7J, U7F.**

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*



*Standard(s) for Safety:*

**UL 429 - Electrically Operated Valves  
CSA C22.2 n°139 - Electrically Operated Valves**

*Additional Information:*

See Addendum for Electrical Ratings

Only those products bearing the UL Recognized Component Marks for the U.S. and Canada should be considered as being covered by UL's Recognition and Follow-Up Service and meeting the appropriate U.S. and Canadian requirements.

The UL Recognized Component Mark for the U.S. generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:  may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual recognitions. The UL Recognized Component Mark for Canada consists of the UL Recognized Mark for Canada:  and the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory.

**Look for the UL Recognized Component Mark on the product**

Issued by:

*Marco Crosignani*  
**Marco Crosignani - Manager CAS II**

Reviewed by:

*Christopher Neilson*  
**Christopher Neilson - Project Engineer**

UL International Italia Srl

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.  
For questions in Italy, you may call +079 2636600.

# Certificate of Compliance

Certificate Number 160604 - E242829  
Report Reference E242829, May 20th, 2004  
Issue Date 2004 June 16

Page 2 of 2



**Underwriters  
Laboratories Inc.®**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UR, cUR requirements.

## ELECTRICAL RATINGS:

Model No.	Voltage (V)	Frequency (Hz)	Current (A)	Power	Duty Cycle
U710	110	DC	0,029	3,2 W	100%
U7H	12	DC	0,258	3,1 W	100%
	24	50/60	0,154	3,5 VA	100%
U77	24	DC	0,13	3,1 W	100%
	48	50/60	0,078	3,5 VA	100%
U771	24	DC	0,13	3,1 W	100%
U75	24	DC	0,093	2,2 W	100%
U73	24	DC	0,210	5 W	100%
U76	110	DC	0,038	4,2 W	100%
U79	48	DC	0,064	3,1 W	100%
U7K	110	50/60	0,033	4,3 VA	100%
	125	50/60	0,043	5.5 VA	100%
U7K1	110	50/60	0,033	4,3 VA	100%
U72	12	DC	0,042	5 W	100%
U74	48	DC	0,110	5,3 W	100%
U71	6	DC	0,850	5,1 W	100%
U7J	230	50/60	0,015	3,5 VA	100%
	240	50/60	0,016	4 VA	100%
U7F	380	50/60	0,019	7 VA	100%

Issued by: *Marco Crosignani* /*pc*  
Marco Crosignani - Manager CAS II

Reviewed by: *Christopher Neilson* /*pc*  
Christopher Neilson - Project Engineer

UL International Italia Srl

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc./UL International Italia Srl